



NOTES:

1. ALL PIPE AND FITTINGS ABOVE GRADE SHALL HAVE FLANGED ENDS.
2. BY-PASS METER ASSEMBLY SHALL BE REQUIRED ON MONITORED FIRE SPRINKLER PROTECTION SYSTEMS.
3. THE CHECK VALVE ASSEMBLY, VALVES AND PIPING AND THE BYPASS METER AND DOUBLE CHECK SHALL BE PAINTED WITH A PRIMER SUITED TO THE BASE MATERIALS AND FINISHED WITH TWO COATS OF EXTERIOR ENAMEL (COLOR IS RED).
4. BYPASS METER AND BACKFLOW PREVENTER SHALL BE ASSEMBLED WITH APPROPRIATE FITTINGS TO ALLOW REMOVAL AND RE-INSTALLATION.

DOUBLE CHECK ASSEMBLY

SEM. CO OCT 2012  
208